

PUBLIC NON-COMMUNITY WATER SYSTEM
NEW WELL WATER TEST REQUIRED PARAMETERS

Microbiological

Total coliform bacteria (E.coli must be tested if total coliform is present)

Volatile Organic Compounds

Benzene
Carbon Tetrachloride
1,2-Dichlorobenzene
1,3-Dichlorobenzene
1,4-Dichlorobenzene
1,1-Dichloroethane
1,2-Dichlorethane
1,1-Dichloroethylene
Cis-1,2-Dichloroethylene
Trans-1,2-Dichloroethylene
1,2-Dichloropropane
Ethylbenzene
Methyl tertiary Butyl Ether
Methylene Chloride
Monochlorobenzene
Naphthalene
Styrene
1,1,2,2-Tetrachloroethane
Tetrachloroethylene
Toluene
1,2,4-Trichlorobenzene
1,1,1-Trichloroethane
1,1,2-Trichloroethane
Trichloroethylene
Vinyl Chloride
Xylenes (total)

Inorganic Compounds

Antimony
Arsenic
Asbestos
Barium

Beryllium
Cadmium
Chromium
Copper
Cyanide (as free Cyanide)
Lead
Mercury
Nickel
Nitrate
Nitrite
Selenium
Thallium

Synthetic Organic Compounds

1,2,3-Trichloropropane
Ethylene Dibromide
1,2-dibromo-3-chloropropane

Radionuclides

Gross alpha Particle Activity

Secondary Compounds

pH
ABS/LAS
Aluminum
Chloride
Fluoride
Hardness (as CaCO₃)
Iron
Manganese
Silver
Sodium
Sulfate
TDS
Zinc
Odor/Color