



Phone (856) 218-4170

Fax (856) 218-4161

Non-public Water Supply System **Sampling Requirements**

<u>Microbiological</u>	
Total Coliform Bacteria	Absent
Fecal coliform bacteria or E.Coli if total coliform is present	Absent
<u>Inorganic Chemicals</u>	MCL (ppm or mg/L)
Lead	0.015 (Action Level)
Mercury	0.002
Nitrate	10 as N
Arsenic	0.005
<u>Secondary Chemicals</u>	MCL (ppm or mg/L)
pH	6.4-8.5 (optimal range)
Iron	0.3
Manganese	0.05
<u>Volatile Organic Compounds</u>	EPA Method 502.2 or 524.2
(26 parameters as required in SDWA)	
<u>Radiological</u>	MCL (pCi/l)
Gross Alpha Activity	15 (Treatment recommended above 5 pCi/l)
<u>Low Level Synthetic Organic Compounds</u>	MCL (ppb or ug/L)
Dibromo-3-chloropropane (1,2)(DCBP)	0.2
Dibromoethane (1,2) (EDB)	0.05
Trichloropropane (1,2,3-TCP)	0.03
<u>PFAS Compounds (effective 12/1/21)</u>	MCL (ppb or ug/L)
PFNA (perfluorononanoic acid)	0.013
PFOA (perfluorooctanoic acid)	0.014
PFOS (perfluorooctanesulfonic acid)	0.013

Updated 11/8/21