

GLOUCESTER COUNTY DEPARTMENT OF HEALTH
 204 E. Holly Avenue
 Sewell, New Jersey 08080
 (856) 218-4170

Distribution System
 (N.J.A.C. 7:10-12.36)

Facility Name	PWSID#	Location Address	Municipality	Block	Lot
Piping Information:	Diameter (in.)	Length (LF)	Material		
Water Main (if applicable):	_____	_____	_____		
Service Lines:	_____	_____	_____		
Fire Hydrant main (if appl):	_____	_____	_____		
Total Length (LF):	_____				

	YES	NO	N/A
1. Is the proposed design capacity of every distribution main and service line such as to provide a minimum pressure of 20 psi at ground level under all flow conditions?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Will the proposed service lines and distribution mains be covered with a minimum of 3.0 feet of earth?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Will service lines and distribution mains be disinfected prior to use in accordance with N.J.A.C. 7:10-12.11?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Are the distribution mains laid in a loop system as much as possible to eliminate dead ends?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Will each dead end have a fire hydrant or flushing device?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6. Is there adequate separation of water service line and sanitary sewer, septic tank, distribution box, disposal field or seepage pit, and cesspool? (N.J.A.C. 7:10-12.36(d))	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
a. Feet from sanitary/industrial sewer line: _____			
b. Feet from septic tank: _____			
c. Feet from septic D-box: _____			
d. Feet from disposal field: _____			
e. Feet from seepage pit: _____			
f. Feet from cesspool: _____			

7. Is there adequate separation of water mains and sanitary or industrial sewers?
(N.J.A.C. 7:10-12.36(e))

a. Feet from sanitary and industrial sewer lines: _____

8. If lateral separation is not possible are the water and sewer lines in separate trenches with the top of the sewer line at least 18 inches below the bottom of the water main in accordance with N.J.A.C. 7:10-12.36(e) ?

9. At sewer crossings, is there adequate separation or protection in accordance with N.J.A.C. 7:10-12.36(e)?

10. Will there be cross connections to a community water system? If so, provide explanation and NJDEP approval on separate page.

11. Will there be cross connections to non-potable service lines (e.g. irrigation, fire suppression)?

12. Will there be back flow preventers on non-potable service lines?

13. Does the distribution main span a stream or water course or fastened to a bridge? If so, please list below:

a. Pipe material: _____

b. Depth of distribution main below water course: _____

***Submit appropriate plans, specifications, reports, etc. to substantiate your answers. ***

I hereby certify that answers provided herein are accurate and reflective of the project being considered for approval.


Signature of Applicant/Owner


Date